



SYRACUSE FIRE DEPARTMENT

CITY OF SYRACUSE, MAYOR SHARON OWENS

Michael J. Monds
Chief of Fire

Elton Davis
First Deputy Chief

Lucas Tortarella
Executive Deputy Chief

Deputy Chiefs
James Farewell
Zachary Smith
Nicholas Pagano
David Munski
George Cowburn

From: Syracuse Fire Department
Fire Prevention Bureau

To: All Mobile Food Preparation Vehicles (Food Trucks) operating in the
City of Syracuse

Re: Mobile Food Preparation Vehicle Inspection Affidavit

Section 4106.4.3 Fuel Gas Systems of the 2025 Fire Code of New York State states:

LP-gas containers installed on the vehicle and fuel-gas piping systems shall be inspected annually by an approved inspection agency or a company that is registered with the U.S. Department of Transportation to requalify LP-gas cylinders, to ensure that system components are free from damage, suitable for the intended service and not subject to leaking. CNG containers shall be inspected every 3 years in a qualified service facility. CNG containers shall not be used past their expiration date as listed on the manufacturer's container label. Upon satisfactory inspection, the approved inspection agency shall affix a tag on the fuel gas system or within the vehicle indicating the name of the inspection agency and the date of satisfactory inspection.

This affidavit, section 1 and 2, must be completed annually and forwarded to the Syracuse Fire Department – Fire Prevention Bureau in order to operate a Mobile Food Preparation Vehicle (Food Trucks) in the City of Syracuse.

Fire Prevention Bureau
Syracuse Fire Dept.
One Park Place
300 South State Street
Syracuse, N.Y. 13202

Office 315 448 4777
Fax 315 448 4779

SFDsprinkler@syr.gov

FirePrevention@syr.gov

FireSafety@syr.gov

www.syr.gov

Section 1: - Vendor Information

Vehicle (Business) Name: (add Unique Identifier for companies with multiple vehicles)	
Responsible Party:	
Business Address:	
Phone #:	
Email :	

Section 2: - Inspection Company Information

Inspection Company:	
USDOT# :	
Address:	
Phone #:	
Email :	
Name of Inspector:	
Inspector Signature:	

Syracuse Fire Department
Fire Prevention Bureau
One Park Place
300 South State Street
Syracuse, New York 13202
315-448-4777
FirePrevention@syr.gov

January 2025

